



Technical Product Sheet - Hammer Union



A division of the WIKA Group

Contact _____

Company _____

Phone _____ Ext _____

Email _____

Address _____

City _____

State _____ Zip _____

Quantity: _____ One Time _____ Recurring _____

Delivery Date Needed _____

Full Scale Range	5K	10K
	15K	20K

Approvals North America (CSA)
IECEX
ATEX

Standard Output: 4-20 mA 2-wire

Shunt Calibration: Y N

Standard Excitation: 10-28 Vdc

Today's Date _____



Optional connector cage

Quantity _____

Standard Electrical Termination

Consult factory for availability of other connector options.

PT02E-10-6P
[Amphenol®, Bendix®]



PTIH -10-6P




MS3102E14S-2P
[Amphenol]



09 3431 700 04
[Binder, Eurofast, M12]



09 3441 700 05
[Binder, Eurofast, M12]



Standard Wiring Codes

Code	E	F	K	A
PIN A	+PWR/SIG	+PWR/SIG	+PWR/SIG	+PWR/SIG
PIN B	-PWR/SIG	-PWR/SIG	-PWR/SIG	-PWR/SIG
PIN C	N/C	+CAL*	N/C	N/C
PIN D	N/C	-CAL*	N/C	N/C
PIN E	+CAL*	GRD	N/C	GRD
PIN F	-CAL*	N/C	N/C	

* Do not wire shunt circuit in hazardous locations.

Other requirements: